



ELECTRICAL RATINGS

LLEOTRIOAE NATINGS	
Rating	
120 VAC, 50/60Hz	
83W	
75W	
FP075: 1A, 40AH maximum	
at 70% of battery voltage	
33 BTU/Hr	
32 to 122F (0 to +50C)	
85% 120VAC 60Hz In, Full Load	
UL294, UL603, UL1076, ULC	
S318, ULC S319, CSA C22.2	
#205, FCC Part 15, Subpart B,	
CSFM IEC 62368-1:2014, EN	
55032:2015, EN6100-3-2:2014,	
EN6100-3-3:2013,	
EN55024:2010+A1:2015, BIS	
IS13252(Part 1):2010, REACH	
209, ROHS 3	

OVERVIEW

Standard Power Systems provide FlexPower power modules in a secure UL listed solution. Standard Power features include:

- Built in Fire Alarm disconnect unlocks doors on a fire alarm
- Low battery cutoff protects batteries from deep discharge
- · Dedicated fast charger prolongs battery life
- Enhanced surge immunity for input/output protection
- Locksafe optimized voltages provide long-term lock protection
- OutSmart Visual LED notification (12V/Green, 24V/Blue)
- Network ready with optional LifeSafety Power NetLink® module
 - Monitor power supply and battery in NetLink dashboard
 - Remote test batteries
- Lifetime Warranty LifeSafety Power's quality commitment

SYSTEM DETAILS

- 1 x FP075 75W Total Output, 120 VAC Input, AC Fault and System Fault form C contacts may be triggered by low/no battery, short to earth ground, power supply failure, or blown fuse
- 1 x F8P (8 FAI Controlled Outputs) 2.5A Class 2 power limited outputs, each output programmable for constant output, enable on FAI, or disable on FAI. Dual buss voltage selection by zone, OutSmart dual color LEDs
- **E1 Enclosure** Size: 14.0H x 12.0W x 4.5D in (35.56 x 30.48 x 11.43 cm)
 - o Enclosure E1
- System Weight 9.45 lbs (4.29kg)

ORDERING

FP075-F8PE1 120 VAC, 75W

AGENCY LISTINGS

US | Canada | Mexico | Europe | UK | India | Australia | New Zealand | RoHS

















LifeSafety Power

10027 S. 51st Street, Suite 102 Phoenix, AZ 85044 USA (888) 577-2898 info1@lifesafetypower.com

Disclaimer:

This datasheet was generated programatically by LifeSafety Power's Online Product Generator on 03/25/2025. Because of this, it may be possible that the model depicted is not possible for LifeSafety $Power to \ build. \ It is the \ responsibility \ of the \ viewer \ of this \ data sheet to \ confirm \ that the \ model \ depicted$ is within the limitations of the product line. Contact LifeSafety Power for confirmation of fitment or $compatibility. \ Specifications \ subject \ to \ change \ without \ notice.$