

Rating

EN6100-3-2:2014, EN6100-3-3:2013, EN55024:2010+A1:2015,

001-SCFI-1933, REACH 209, ROHS 3, RCM AS/NZS 4417.1,

SAA AS/NZS 62368.1:2018

BIS IS13252(Part 1):2010, NOM-

120 VAC, 0W

# OVERVIEW

Power Systems provide FlexPower power modules in a secure UL listed solution. Standard Power features include:

- Built in Fire Alarm disconnect unlocks doors on a fire alarm
- Low battery cutoff protects batteries from deep discharge
- Dedicated fast charger prolongs battery life
- Enhanced surge immunity for input/output protection
- Locksafe optimized voltages provide long-term lock protection
- OutSmart Visual LED notification (12V/Green, 24V/Blue)
- Network ready with optional LifeSafety Power NetLink® module
  - Monitor power supply and battery in NetLink dashboard
  - Remote test batteries
- Lifetime Warranty LifeSafety Power's quality commitment

# SYSTEM DETAILS

# ORDERING

RFP075-DC RearNL4RS-D8M8RS8

# AGENCY LISTINGS

US | Canada | Mexico | Europe | UK | India | Australia | New Zealand | RoHS



### Input Voltage 120 VAC, 50/60Hz Input Power (max) 0W Output Power 0W Maximum Charge Current 0 Low Power Disconnect at 70% of battery voltage Systems BTU/Hr 0 BTU/Hr **Operating Temperature** 32 to 122F (0 to +50C) Efficiency 0% 120VAC 60Hz In, Full Load UL294, UL1076, ULC S318, ULC Agency Approvals S319, CSA C22.2 #107.1, FCC Part 15, Subpart B, CSFM IEC 62368-1:2014, EN 55032:2015,

ORD

ELECTRICAL RATINGS

Parameter

## LifeSafety Power

10027 S. 51st Street, Suite 102 Phoenix, AZ 85044 USA (888) 577-2898 info1@lifesafetypower.com

### Disclaimer:

This datasheet was generated programatically by LifeSafety Power's Online Product Generator on 04/01/2025. Because of this, it may be possible that the model depicted is not possible for LifeSafety Power to build. It is the responsibility of the viewer of this datasheet to confirm that the model depicted is within the limitations of the product line. Contact LifeSafety Power for confirmation of fitment or compatibility. Specifications subject to change without notice.